
Note

To: Fay Eames- County Planning
From: Stewart Rose- Highways Development Planning
Our Reference: 6/3/1/MIN
Copies to:
Date: **26 April 2013**

Subject: **Renewal of fencing to portion of northern boundary with higher metal fencing and provision of metal fencing to section of southern boundary, Fort Hill School, Kenilworth Road, Basingstoke Hampshire RG23 8JQ**

Thank you for the opportunity to comment on the above application. The applicant seeks to replace a failing wooden 1.2m high perimeter fence with a 2m high metal fence. This is to stop unauthorised access and egress from the Secondary School.

Once completed, the fence will have no impact on the highway. It will not create or remove any vehicle or pedestrian accesses. However, the construction of the fence will have a temporary impact on the highway due to deliveries and contractor parking.

A construction management plan has not been submitted. If the work is to be completed during school holidays, the Construction Management plan is required to detail where contractors will park, measures to prevent mud and spoil entering the highway or reasons why wheel washing facilities are not necessary.

However, if the works are to be undertaken during school term time, a more holistic Construction Management Plan is required. In addition to the above, the Construction Management Plan will also need to detail the construction compound separating pupils from the construction, and hours of operation during the school day.

I trust that the above is clear, but do not hesitate to contact me if you wish to discuss this further.

Recommendation: Subject to the following, I have no objection to the above development from a highways and transport perspective:

No part of the development hereby approved shall be commenced until such time as a Construction Management Plan has been submitted to and approved by the Waste Planning Authority, detailing contractor parking provisions, measures to prevent mud and spoil entering the highway, the hours and dates of operation and the extent and of the construction compound. The approved details shall be implemented before the development hereby permitted is commenced and retained throughout the duration of construction.

Reason: In the interest of highway safety.

I trust that the above is clear but I would ask you not to hesitate to contact me should you wish to discuss anything further.