

East Hampshire District Council

Penns Place, Petersfield, Hampshire, GU31 4EX

Direct Dial: 01730 234323 Direct Fax: 01730 234330 E-mail: david.fitzgerald@easthants.gov.uk

Memorandum

To: HCC Planning
From: David Fitzgerald
Our Ref: **CONS/66952/12**
Your Ref: F22689/002/FUL
Date: 18 July 2012

Re: Beacon House, Mill Lane, Alton, GU34 2PH

The noise assessment that has been provided is not a comprehensive enough to provide an informed decision. Given this **I would not recommend** removing the condition from the associated planning permission.

A BS4142 assessment needs to be undertaken on the worst 5 minute period during the night time and also the worst 1 hour period during the day. Calculations need to be provided on the noise that may be associated with that period and determine the noise rating, at the boundary of the residential dwelling.